



SERIES 4600F
12 x 8 x 18 F

FILE NO: F46.691
 DATE: Feb. 20, 2008
 SUPERSEDES: New
 DATE: New

HSC Pump


DIESEL DRIVEN

SUBMITTAL

JOB: _____ REPRESENTATIVE: _____

 ENGINEER: _____ ORDER NO: _____ DATE: _____
 CONTRACTOR: _____ SUBMITTED BY: _____ DATE: _____
 _____ APPROVED BY: _____ DATE: _____

TAG/REF:								
PUMP DATA	FLOW	HEAD	ENGINE DATA	HP	RPM	BAT. VOLTAGE	TANK SIZE	OTHER



ENGINE	DIMENSIONS (Inches)								WEIGHT lbs.
	HD	Z	HA	HE	HB	HF	HM ⁽³⁾	C ⁽⁴⁾	
CLARKE									
JU6H SERIES	29.25	16.50	32.00	30.00	106.00	51.00	60.05	103.75	2000
JW6H SERIES	29.25	16.50	32.00	30.00	106.00	51.00	59.83	103.00	2600
JX6H SERIES	29.25	16.50	32.00	30.00	118.00	57.00	46.88	115.75	3250
CUMMINS									
CFP59 SERIES	29.25	16.50	32.00	30.00	98.00	47.00	53.94	95.13	1138
CFP83 SERIES	29.25	16.50	32.00	30.00	102.00	49.00	53.75	101.50	1792
CFP6E SERIES	29.25	16.50	32.00	30.00	98.00	47.00	52.75	95.50	1257
CFP11E SERIES	29.25	16.50	40.00	38.00	110.00	53.00	55.75	108.75	2343

- FLANGE RATING**
- ANSI 125# STD⁽¹⁾
 - ANSI 125# SUCTION
250# DISCHARGE
 - ANSI 250#
 - PN 16
- FIRE PUMP LISTING**
- UL
 - ULC
 - FM
- ACCESSORIES**
- EXHAUST SYSTEM (4)
 - FUEL SYSTEM (4)
 - COOLING SYSTEM (MOUNTED ON ENGINE)
 - BATTERY SYSTEM (4)

NOTE:
 (1) STD. DISCHARGE FLANGE THICKNESS ANSI 250#
 (2) COUPLING GUARD SHOWN IN OUTLINE
 (3) ALL DIMENSIONS FOR ENGINE CONNECTIONS ARE WITH REFERENCE TO ENGINE MANUFACTURER'S INSTALLATION DRAWINGS
 (4) TO BE SHIPPED LOOSE WITH PACKAGE

RIGHT HAND ROTATION ONLY
 (AS SHOWN)

DO NOT USE FOR CONSTRUCTION UNLESS CERTIFIED

S. A. Armstrong Limited 23 Bertrand Avenue Toronto, Ontario Canada, M1L 2P3 T: (416) 755-2291 F (Main): (416) 759-9101	Armstrong Pumps Inc. 93 East Avenue North Tonawanda, New York U.S.A. 14120-6594 T: (716) 693-8813 F: (716) 693-8970	Armstrong Holden Brooke Pullen Wenlock Way Manchester United Kingdom, M12 5JL T: +44 (0) 161 223 2223 F: +44 (0) 161 220 9660
--	---	---



© S.A. Armstrong Limited 2008

For Armstrong locations worldwide, please visit www.armstrongpumps.com